



ADDENDUM No.4

Date: April 12, 2022

To: Prospective Bidders

Subject: Addendum #4-GPL-PD-003-2022

1. Further Requirements

- There is now a requirement for five (5) 72.5 kV SF6 Circuit Breakers as opposed to the three(3) previously being requested. This is due to there being a requirement for a different circuit breaker arrangement as per the approved D&E plan.
- There is now a requirement for ten(10) 72.5 kV 3 Phase Disconnect Switch with Earthing Mechanism as opposed to the six(6) previously requested. This is due to there being a requirement for a different circuit breaker arrangement as per the approved D&E plan.
- Bidders are required to include a quotation that will cover the component of supervision of the installation/commission of equipment being supplied.

Please see below Single Line Diagram

All other terms and conditions remain unchanged. Please be guided accordingly.



Ganesh Persaud,

Procurement Manager (ag).