



ADDENDUM No.2

Date: July 15, 2019

To: Prospective Bidders

Subject: Addendum No.2 – Supply of Single Phase Transformer – GPL PD 023 – 2019.


Technical Specifications

Item 12: Losses

Transformer losses will be capitalised and added to the Bid Price for bid evaluation as follows:

- a) No-load Losses = US\$ 27.99 /kW
- b) Load Losses = US\$ 9.19 /kW

All other terms and conditions remain unchanged. Please be guided accordingly.


.....
Anthony Johnson
Procurement Manager
Guyana Power & Light Inc.