



ADDENDUM No.1

Date: April 9, 2020


Subject: Addendum No.1 – Supply of Concentric Cables – GPL-PD-002-2020.

To: Prospective Bidders

Based on logistic and other challenges being faced by prospective bidders in completing their bids for a timely submission, GPL Inc. has taken a decision to extend this tender until **Friday, June 12, 2020**. Simultaneously as we give notice of the extension, it is fitting that the Company provides the following clarifications relative to the technical specifications of the Bid:

1. Quantities of the assorted cables are as stated in tender document;
2. The correct specifications are 2xNo.2 AWG duplex and 3xNo.2 AWG triplex;
3. Correct type is 2x2AWG+1x6AWG;
4. No. of threads for the neutral conductor is 13;
5. Conductor sizes 8-2 AWG and 1/0 - 4/0 & 1.14mm and 1.40mm respectively;
6. Certificate must be issued by an institution in the country of origin that has been approved by ISO or any other accredited recognized authority;
7. Correct temperatures are 90°C, 130°C and 250°C respectively;
8. Sample size is a foot each of duplex and triplex cables; and
9. No alternative Bids are allowed.

All the other terms and conditions remain unchanged. Please be guided accordingly as we invite you to continue visiting our website for further updates, until the closing of Bid No. **GPL-PD-002-2020**



Anthony Johnson
Procurement Manager
Guyana Power & Light Inc.