



ADDENDUM No. 03

Date: February 7, 2022

To: Prospective Bidders

Subject: Addendum No. 3 – Construction of Control Building and Foundation for Generators at New Friendship, Wakenaam – GPL-PD-001-2022

Changes to Tender Document:

Changes have been made to the following sections:

Update to Bid Data Sheet

- **ITB 9.3** changed to “The Employer at any time before expiry of the deadline for submission of bids may vary the quantities by **20 percent** increase or decrease.”

Update to Drawings

- Updated contract drawings are attached and must be used as the tender drawings.

Update to Bill of Quantities

- Revision 02 of the Bill of Quantities (BOQ) is attached and must be used as the tender BOQ.

Update to Technical Specifications, Section 000 – General, page 69

- Section 002 – Documents

Disregard the contents of this section and instead use the following:

“These specifications shall be read in conjunction with the following provided in Addendum No. 02:

- a) Contract Drawings
- b) Revision 02 of the Bill of Quantities
- c) Accompanying exhibit document, titled **Technical Specifications for Low Voltage System for Wakenaam Power Plant**”

- Section 003 – Description of Works to be undertaken

Disregard the contents of this section and instead use the following:

The works to be completed are as follows:

- a) Construction of a 14.2m x 14.2m steel frame Control Building, along with
- b) Concrete cable trenches
- c) Concrete engine slab
- d) Concrete plinths for transformers
- e) Supply and installation of building and site electrics
- f) Supply and installation of station grid and grounding
- g) Supply and installation of lightning arrestors
- h) Construction of interior road around the building
- i) Demolition of the old Transmission and Distribution building
- j) Dismantling and re-erection of lube oil shed
- k) Realignment of fuel line

All other terms and conditions remain unchanged. Please be guided accordingly.

Best Regards,


.....
2022/02/01

Ganesh Persaud

GUYANA POWER & LIGHT INC.
PROCUREMENT MANAGER