



## ADDENDUM No.2

**Date:** December 8th, 2022  
**To:** Prospective Bidders  
**Subject:** GPL-PD-063-2022: CONSTRUCTION OF 25 MW  $\pm$ 5% HFO FIRED  
POWER GENERATION PLANT

---

### Amendment to Clause 21.1 Description of Project:

Sub Clause **21.1.1 (Page 148)** is amended to read as follows:

The Plant shall be constructed on either: (1) site contiguous to the existing Power Plant Compound located at Canefield, East Berbice, or (2) site adjoining 69/13.8kV Substation, Columbia, Mahaicony, East Coast Demerara. Both sites are shown on the Google Earth Maps (Drawing # 01 & 02). The scope shall be executed by an EPC Contractor working under a Lump Sum Turn Key (LSTK) Contract.

At Canefield Power Station, the Plant shall be connected to the new 60 MVA 69 KV/13.8 KV Transformer and new Transformer Bay in the Substation.

### Addition to Clause 21.2 Statement of Work

Sub Clause **21.2.12 (Page 149):** Engineering, procurement and construction of all Transformer related works required for the replacement of the existing 16.7 MVA 13.8KV/69KV Transformer.

### Amendment to Clause 17.4.9 – Electrical Systems

Sub Clause **A8.1b** –Substation Transformer is amended to read as follows:

One (1) 60 MVA 13.8 KV/69 KV 60 Hz ONAN Substation Transformer and all other transformer related works required for the replacement of the existing 16.7 MVA 13.8 KV/69KV Transformer in the Canefield Substation.

All others terms and conditions remain unchanged. Please be guided accordingly.



Ganesh Persaud,  
Supply Chain Manager, Procurement,  
Strategic Operations.